

- 10 Year Warranty

- Insulating Glass Units (EN1279)

- Frame Types:
 - PVC
 - Aluminium
 - Hardwood (Factory Glazed)

- Faults Covered :
 - Edge Seal Failure

Product Range Covered by This Warranty

This Warranty covers all standard type insulating glass units compliant with EN1279 and incorporating only components of the type listed below:

Glass

- 4mm – 12mm annealed, rolled or toughened glass
- 4.4mm – 13.5mm laminated safety glass

Spacer Bar

- 10mm – 20mm aluminium spacer bar
- 10mm – 20mm warm edge plastic and stainless steel spacer bar

Edge Seal

- Butyl primary seal
- Polysulphide or silicone secondary seal

Product Application Covered by This Warranty

This Warranty covers all standard type insulating glass units, fully framed and glazed into one of the following type of systems, where adequate drainage is provided by the framing system:

- uPVC window frames, doors and conservatories
- Aluminium curtain walling, windows and doors
- Hardwood windows and doors – factory glazed only

Warranty Period and Details

If, within ten years from date of dispatch from our works, the unbroken double glazed unit is, through faulty manufacture, affected by material visual obscuration because of condensation or dust collection within the double glazed unit, we will, subject to compliance with the claims procedure outlined below, supply replacement product without charge.

This Warranty only provides for free replacement of the product or refund of the original invoice value and does not cover consequential damage.

No liability is accepted for personal injury, loss, claims, property damage, or labour, material or other costs howsoever caused or arising and whether direct or indirect.

This warranty applies only to units installed in normal service conditions within the United Kingdom and the Republic of Ireland.

Conditions of Warranty

This warranty is subject to the following conditions:

- That the buyer acknowledges that the product at the time of delivery was undamaged and free from any defects
- That the product is protected from contact with wet cement, hard foreign objects, metals and materials likely to cause abrasive damage

Exclusions to Warranty

This warranty excludes:

- Minor imperfections inherent in architectural glass and that caused during the manufacturing process whenever viewed in accordance with the Glass & Glazing Federation 'Visual Quality Standard' for installed insulating glass units constructed from flat transparent glass.
- Units which have not been transported, handled, stored, installed and maintained completely in accordance with the glazing instructions laid down in the Glass & Glazing Federation 'Glazing Manual'
- Stepped units and drip edge units where the sealant is not protected from ultra-violet light in service
- Units displaying the optical phenomenon, occasionally seen as interference colour bands, known as 'Brewster's Fringes'
- Distortion caused by the toughening process, ie. 'rollerwave' distortion
- Units exceeding GlasSeal recommended maximum sizes (see Appendix)
- Units used in service conditions such as (but without limitation) use in transport vehicles, ships or temperature cabinets, or use at altitude over 600 metres or transportation of units over such elevation
- Carbon deposits on the outer face of decorative leaded units caused by oxidation of the lead
- Units with glass 'inserts' – ie. panes inserted into the unit cavity during unit assembly (such glass can be guaranteed if manufactured as conventional triple glazed units)
- Curved double glazing units comprising panes of 'curved-on-plan' glass
- Units which have had decorative, safety or solar adhesive film applied to either interior or exterior surfaces



Making a Warranty Claim

Reporting a Failure

- Any failure of the product should be reported in writing to GlasSeal within 14 days of its occurrence.
- Proof of purchase must be provided.
- It is a condition of this warranty that a GlasSeal representative is afforded reasonable opportunity to inspect the product prior to de-glazing.

Investigation of Complaint

- Inspection should establish the nature, extent and cause of the fault
- If this finding is consistent with faulty manufacture and within the conditions of this Warranty then a claim may be made under this Warranty

Replacement Product

- If a replacement unit is supplied, it will be our standard type of product current at the time of replacement
- The replacement product shall be covered by a 1 year warranty or up to the limit of the warranty period covering the original unit, whichever is later

Appendix

Maximum Unit Sizes

glass	cavity	glass	max. area	max. length
4 float	10mm	4 float	2.0m ²	2400mm
4 float	12-20mm	4 float	3.0m ²	2400mm
4 tough	10mm	4 tough	2.0m ²	2400mm
4 tough	12-20mm	4 tough	3.0m ²	3600mm
6 float	10mm	6 float	3.0m ²	3200mm
6 float	12-20mm	6 float	4.8m ²	3200mm
6 tough	10mm	6 tough	3.0m ²	3600mm
6 tough	12-20mm	6 tough	6.0m ²	3600mm
6 tough	10mm	6.4 lam	3.0m ²	3200mm
6 tough	12-20mm	6.4 lam	4.8m ²	3200mm
6.4 lam	10mm	6.4 lam	3.0m ²	3200mm
6.4 lam	12-20mm	6.4 lam	4.8m ²	3200mm
8 tough or 8.8 lam	10mm	8 tough or 8.8 lam	5.0m ²	3200mm
8 tough or 8.8 lam	12-14mm	8 tough or 8.8 lam	6.5m ²	3200mm
8 tough or 8.8 lam	16-20mm	8 tough or 8.8 lam	8.0m ²	3750mm